#### **DATASHEET - M22S-WRK3**



#### Selector switch, toggle, 3 positions, black, maintained

Part no. M22S-WRK3 Catalog No. 216873 Eaton Catalog No. M22S-WRK30



**Delivery program** 

zomor, program		
Product range		RMQ-Titan
Basic function		Selector switch actuators
Single unit/Complete unit		Single unit
Design		With thumb-grip
		maintained
Function:		
		60° # 60°
		3 positions
Degree of Protection		IP66
Front ring		Bezel: black
Connection to SmartWire-DT		yes with SWD-RMQ connections
Actuator travel and actuation force as per DIN EN 60947-5-1, K.5.4.1		
Minimum force for positive opening	N	0
Front dimensions		29,7
Instructions		Stay-put/spring-return function, can be changed with coding parts M22-XC-Y with plunger bridge for the middle contact

## **Technical data**

General

General			
Standards			IEC/EN 60947 VDE 0660
Lifespan, mechanical	Operations	x 10 <sup>6</sup>	> 0.1
Operating frequency	Operations/h		≦ 2000
Operating torque (screw terminals)		Nm	≦ 0.3
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Degree of Protection			IP66
Ambient temperature			
Open		°C	-25 - +70
Storage		°C	- 40 - + 80
Mounting position			As required
Mechanical shock resistance		g	30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27
Indoor and protected outdoor installation			

# Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	0
Heat dissipation per pole, current-dependent	$P_{\text{vid}}$	W	0
Equipment heat dissipation, current-dependent	$P_{\text{vid}}$	W	0
Static heat dissipation, non-current-dependent	$P_{vs}$	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
EC/EN 61439 design verification			

10.2 Strength of materials and parts	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	Not applicable.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 6.0**

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss8.1-27-37-12-13 [AKF031011])


Number of switch positions       4       4       3         Type of control element       50 pgle       70 pgle         Suitable for illumination       No       70 pgle         Colour control element       80 pgle       81 pgle         Colour indicator light cap       Not applicable         Construction type lens       80 nd         Hole diameter       mm       22.5         Width opening       mm       0         Height meter opening       mm       0         Switching function latching       mm       0         Spring-return       No       79 pg         Degree of protection (IP), front side       P66       1966         With front ring       Pastic       19 plastic         Colour front ring       19 plastic       19 plastic			
Suitable for illumination Colour control element Black Colour indicator light cap Construction type lens Hole diameter Width opening Height meter opening Switching function latching Spring-return Degree of protection (IP), front side With front ring Material front ring Material front ring  No  No  No  No  No  No  Plastic	Number of switch positions		3
Colour control element Colour indicator light cap Construction type lens Hole diameter Width opening Height meter opening Switching function latching Spring-return Degree of protection (IP), front side With front ring Material front ring Material front ring  Black Not applicable Round  Round  Pau 22.5  Round  Pau  Pau  Pau  Pau  Pau  Pau  Pau  Pa	Type of control element		Toggle
Colour indicator light cap  Construction type lens  Hole diameter  mm  22.5  Width opening  mm  0  Height meter opening  Switching function latching  Spring-return  Degree of protection (IP), front side  With front ring  Material front ring  Not applicable  Round  Round  0  22.5  No  0  1  1  1  1  1  1  1  1  1  1  1  1	Suitable for illumination		No
Construction type lens  Hole diameter  mm 22.5  Width opening  mm 0  Height meter opening  mm 0  Switching function latching  Spring-return  Degree of protection (IP), front side  With front ring  Material front ring  Round  Round  Round  No  Plastic	Colour control element		Black
Hole diameter mm 22.5  Width opening mm 0  Height meter opening mm 0  Switching function latching Yes  Spring-return No  Degree of protection (IP), front side IP66  With front ring Yes  Material front ring Plastic	Colour indicator light cap		Not applicable
Width openingmm0Height meter openingmm0Switching function latchingYesSpring-returnNoDegree of protection (IP), front sideIP66With front ringYesMaterial front ringPlastic	Construction type lens		Round
Height meter opening mm 0  Switching function latching Yes  Spring-return No  Degree of protection (IP), front side IP66  With front ring Yes  Material front ring Plastic	Hole diameter	mm	22.5
Switching function latching Yes  Spring-return No  Degree of protection (IP), front side With front ring Yes  Material front ring Plastic	Width opening	mm	0
Spring-return No Degree of protection (IP), front side IP66 With front ring Yes Material front ring Plastic	Height meter opening	mm	0
Degree of protection (IP), front side  With front ring  Yes  Material front ring  Plastic	Switching function latching		Yes
With front ring  Yes  Material front ring  Plastic	Spring-return		No
Material front ring Plastic	Degree of protection (IP), front side		IP66
	With front ring		Yes
Colour front ring Black	Material front ring		Plastic
	Colour front ring		Black

# Approvals

••	
Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	012528
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type 3R, 4X, 12, 13

# Dimensions





#### **Assets (Links)**

**Declaration of Conformity** 00002596

### **Additional product information (links)**

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan System

ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716002Z2017\_01.pdf